



## TECHNICAL DATA n°

**F1336BYSA01 00**

### Non breathing hermetically sealed transformer

phase number	<b>Three</b>	insulating liquid	<b>Oil</b>	oil type	<b>SANS 555</b>					
<b>INSTALLATION</b>										
Operating cooling air ambient temperature	<b>Step down ONAN</b> <b>40 °C</b>	type max. sea level normative referencee	<b>Pole monted</b> <b>1 800 m</b> <b>SANS 60076</b>	installation	<b>outdoor</b>					
<b>ELECTRICAL CHARACTERISTIC</b>										
rated power	<b>315 kVA</b>	frequency	<b>50 Hz</b>	vector group						
sound power level	<b>48 dBA</b>	temperature rise	<b>60 K</b>	winding	<b>Dyn11</b>					
		no load losses	<b>550 W</b>		<b>65 K</b>					
		load losses at 75°C	<b>3800 W</b>							
		total losses	<b>4350 W</b>							
			<b>+15%</b>							
			<b>+15%</b>							
			<b>+10%</b>							
<b>Primary</b>										
voltage	<b>22 000 V</b>			<b>420 V</b>						
Off-load tap changing (%)	<b>+2 x 2,5%</b>									
Off-load tap changing (V)	<b>+2 x 275V (+-0,4 %)</b>									
vector group	<b>D</b>			<b>yn</b>						
Highest voltage for hte equipement	<b>12 kV</b>			<b>1,1 kV</b>						
Power frequency whistand voltage	<b>28 kV</b>			<b>3 kV</b>						
Rated lightning impulse voltage	<b>95 kV</b>			<b>30 kV</b>						
Short-circuit impedance	<b>4,5 % ( +10% )</b>									
rated current	<b>8.27 A</b>			<b>433 A</b>						
Winding conductor material	<b>Al</b>			<b>Al</b>						
<b>efficiency</b>										
	<b>Power factor = 1</b>	<b>Power factor = 0,8</b>	<b>voltage drop</b>	<b>Power factor = 1</b>	<b>Power factor = 0,8</b>					
Load =100%	<b>98,49%</b>	<b>98,12%</b>	Load =100%	<b>1,44 %</b>	<b>3,69 %</b>					
75%	<b>98,76%</b>	<b>98,46%</b>	80%	<b>1,14 %</b>	<b>2,95 %</b>					
50%	<b>98,98%</b>	<b>98,72%</b>								
25%	<b>98,95%</b>	<b>98,70%</b>								
<b>DIMENSIONS</b>										
Drawing	<b>4081449</b>									
<b>TANK PROTECTION</b>										
Sandblasting, zinc plating 60µ epoxy powder 40µ (Total 100µ)										
Finishing: DS14 + DS15										
				<b>Color</b>	<b>navy light grey G35</b>					
<b>TESTS</b>										
<b>Routine tests systematically performed on each transformer and object of a certificate :</b>										
<ul style="list-style-type: none"> <li>- Voltage ratio measurement</li> <li>- Winding resistance measurement</li> <li>- Short duration power withstand voltage on each winding</li> <li>- Short-circuit characteristics measurement .</li> </ul>			<ul style="list-style-type: none"> <li>- Load losses, Short-circuit impedance</li> <li>- No-load losses and current measurement</li> <li>- Induced voltage withstand test at twice the rated voltage during 30 seconds at 200Hz</li> </ul>							
<b>RED-73-E-008aj</b> Index	<b>Date</b> <b>2018/06/07</b>	<b>Autor</b> <b>KM</b>	<b>Checker</b> <b>MB</b>							